

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 1450-1342:111 Page 1 of 1

CATEGORY: Expansion Joints

LISTEE: Watson Bowman Acme, 95 Pineview Drive, Amherst NY 14228
Contact: John Sobol (716) 691-7566 Fax (716) 691-9239

DESIGN: Model WABOCRETE Membrane 201 system. Refer to listee's data sheet (05800/WAT BuyLine 2397 WB210-1993) for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Warnock Hersey label.

APPROVAL: Listed as an expansion joint where 2-hour fire-rated protection is needed.

02-16-93



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**